



Product Service

Attestation of Conformity

No. N8 14 06 86602 001

Holder of Certificate: Hangzhou EVT Electrical Co., Ltd.Huantan Industrial Zone, Jinhua Town, Xiaoshan District
311253 Hangzhou

PEOPLE'S REPUBLIC OF CHINA

Product:**Pliable plastic conduits
Flexible Conduit and Accessories**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.:

7041013122901-00

**Date,** 2014-06-23

(Yi Zhu)



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



Product Service

Attestation of Conformity

No. N8 14 06 86602 001

Model(s): **GFC Series, PFC Series, LTC Series, 150 Series, 100 Series, 470 Series, 490 Series, 401 Series, 411 Series**

Parameters:

Diameter:			
Name	Model	Specification	
Flexible Steel Conduit	GFC series	3/8", 1/2", 3/4", 1", 1-1/4", 1-1/2", 2", 2-1/2", 3", 4"	
PVC Coated Flexible	PFC series	3/8", 1/2", 3/4", 1", 1-1/4", 1-1/2", 2", 2-1/2", 3", 4"	
Liquid Tight Conduit	LTC series	3/8", 1/2", 3/4", 1", 1-1/4", 1-1/2", 2", 2-1/2", 3", 4"	
Squeeze Connector	150 series, 100 series	3/8", 1/2", 3/4", 1", 1-1/4", 1-1/2", 2", 2-1/2", 3", 4"	
Liquid Tight Connector	470 series, 490 series	3/8", 1/2", 3/4", 1", 1-1/4", 1-1/2", 2", 2-1/2", 3", 4"	
Liquid Tight Coupling	401 series, 411 series	1/2", 3/4", 1"	
Classification:	3352		

Tested according to:

EN 61386-1:2008
EN 61386-23:2004